

CS/B.TECH/EIE(New)/SEM-6/EI-601/2013

2013

PROCESS CONTROL - I

Time Allotted : 3 Hours

Full Marks : 70

The figures in the margin indicate full marks.

*Candidates are required to give their answers in their own words
as far as practicable.*

GROUP – A

(Multiple Choice Type Question)

1. Choose the correct alternatives for the following: 10 x 1 = 10
 - i) Brain of process control loop is
 - a) a controller
 - b) actuator
 - c) valve
 - d) all of these.

 - ii) Ratio control system is a special type of
 - a) open loop control system
 - b) ON-OFF control system
 - c) feed forward control system
 - d) feedback control system

- iii) Controller output for a time-proportional control action is
- a) proportional to the time
 - b) continuous in nature
 - c) discrete in nature
 - d) none of these.
- iv) What type of controller is used for elimination for offset?
- a) P-controller
 - b) I-controller
 - c) D-controller
 - d) time-proportional controller.
- v) A cascade controller is used when the process
- a) gain is too small
 - b) gain is too large
 - c) has widely different two constants
 - d) oscillation of the output is not permitted.
- vi) Ziegler-Nichols tuning technique is a/an
- a) open loop procedure
 - b) closed loop procedure
 - c) semi-open loop procedure
 - d) semi-closed loop procedure.
- vii) D-Control action is realized using
- a) Ramp signal
 - b) Step signal
 - c) Sinusoidal signal
 - d) both (a) & (c).
- viii) Which valve is used for pressure control?

- a) Globe valve b) Butterfly valve
 c) Check valve d) None of these.
- ix) Response of feed forward control is than feedback control.
 a) moderate b) faster
 c) slower d) none of these.
- x) Valve-positioner is a high gain
 a) P-controller b) D-controller
 c) PI-controller d) I-controller
- xi) Which type of isolator is generally used in I/O module of PLC?
 a) Electrical isolator
 b) Optical isolator
 c) Magnetic isolator
 d) Electronic isolator

GROUP – B

(Short Answer Type Questions)

Answer any *three* of the following. 3 x 5 = 15

2. What is a servo loop? Explain it with a proper diagram. How does it differ from a process control loop? 1 + 3 + 1
3. What is reset action? Prove that $P.B = 100/K_c$, where symbols have their usual meaning. 1 + 4
4. Draw the block diagram of a basic process control loop and describe the function of each block in brief.
5. Explain with a neat sketch how feed forward control is implemented for the temperature control in a heat exchanger system.

6. What do you mean by double seated valve? Why is it advantageous over single seated valve? 3 + 2

GROUP – C

(Long Answer Type Questions)

Answer any *three* of the following. 3 x 15 = 45

7. a) What is the major problem of proportional controller when set point is changed.
- b) Why is derivative control not used alone?
- c) Explain the principle of operation of On-Off controller. Explain the function of differential gap or neutral zone on the performance of On-Off controller.
- d) Discuss analytically the problem for the proportional controller in a first order process.
- e) Explain analytically how the problem can be eliminated using the proportional signal (PI) controller.
- $1 + 2 + 2 + 2 + 4 + 4$
8. a) Draw the block diagram of PLC and explain briefly the principle of operation.
- b) What are the differences between retentive and non-retentive timer PLC?
- c) A selection committee comprises four members including the chairman. In order for a candidate to be selected, he or she has to have the support of at least 2 members. The chairman, however, can push any candidate though. If each member is provided with a switch, determine a logic that will ring a bell when a candidate is selected & draw the ladder diagram for this. 5 + 4 + 6
9. a) Explain the operating principle of a pneumatic actuator with suitable diagram.

- b) Draw and explain the equal percentage valve characteristics.
- c) Draw and explain the operation of a spring actuator valve with positioner.
- d) A 1.5 inch control valve has the linear characteristics with the following specification:

At 30% valve opening, $C_v = 9.6$

At 40% valve opening, $C_v = 13.3$

At 80% valve opening, $C_v = 25.9$

Calculate C_v at 90% valve opening. 3 + 2 + 5 + 5

- 10. a) What are the different tuning schemes proposed for a PID controller? How have they been evolved? 10 + 5
- b) How can the controllability of a process assessed from the process reaction curves? 10 + 5
- 11. Write short notes on any *three* of the following: 3 x 5
 - a) Solenoid valve
 - b) Cascade control
 - c) Safety valve
 - d) I/P converter
 - e) Override control.

=====